

ADDENDUM NO. 1
BOGGS ROAD SANITARY SEWER IMPROVEMENTS
CONTRACT TBD-2025
MUSKINGUM COUNTY COMMISSIONERS

Bids will be received until 10:00 A.M. Local Time on October 16, 2025.

This Addendum to the Project Manual / Project Plans is issued to modify, explain, or correct the original Project Manual / Project Plans and is hereby made part of the Contract Documents. Insert the number of this Addendum in the blank space provided in the Bid, Page 23 of 477.

A. PROJECT MANUAL

1. ADVERTISEMENT FOR BIDS

- a. Page 4 of 477

REPLACE:

Owner anticipates that the Project's total bid price will be approximately \$433,088.60. The Project has an expected duration of 300 days to Substantial Completion and 360 days to Final Completion.

With:

Owner anticipates that the Project's total bid price will be approximately \$433,088.60. The Project has an expected duration of 240 days to Substantial Completion and 300 days to Final Completion.

2. SECTION 1.6 - MANHOLE AND INLET/CATCH BASIN CASTINGS

- a. Page 426 of 477 (first paragraph)

REPLACE:

All manhole and inlet/catch basin castings shall be ductile iron and meet the requirements of ASTM A48. All castings for sanitary sewer manholes shall be Neenah Foundry R-1556 or R-1556- A, subject to the County's approval, with top surface alternate lettering "MUSKINGUM COUNTY SANITARY", or equal. Unless otherwise shown on the drawings or specified in the SPECIAL PROVISIONS, standard storm sewer manhole castings shall be as shown on ODOT Standard Construction Drawing MH-3.

With:

All manhole and inlet/catch basin castings shall be ductile iron and meet the requirements of ASTM A48. All castings for sanitary sewer manholes shall be Neenah Foundry R-1642 or R-1642- A, subject to the County's approval, with top surface lettering "SEWER", or equal. Unless otherwise shown on the drawings or specified in the SPECIAL PROVISIONS, standard storm sewer manhole castings shall be as shown on ODOT Standard Construction Drawing MH-3.

3. SECTION 12.2 - SECTION 1.6 MANHOLE AND INLET/CATCH BASIN CASTINGS

- a. Page 473 of 477 (first paragraph)

REPLACE:

Standard manhole castings for sanitary sewer shall be Neenah Foundry R-1556 or R-1556-A, subject to the County's approval, with top surface alternate lettering "MUSKINGUM COUNTY SANITARY", or equal.

With:

Standard manhole castings for sanitary sewer shall be Neenah Foundry R-1642 or R-1642-A, subject to the County's approval, with top surface alternate lettering "SEWER", or equal.

Replace these 49 pages with the attached revised pages of the same number in the Project Manual. These pages are provided as a separate pdf titled **"001 MUS-Boggs-Addendum No 1-Project Manual"** with this addendum.

B. PLANS

1. REPLACE Drawing Sheets 01/18 and 04/18 with the attached Revised Drawing Sheets of the same number with a "Revised Date" of October 6, 2025. These two sheets are provided as a separate pdf titled **"001 MUS-Boggs-Addendum No 1-Plans"** with this addendum.

**BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE
SPACE PROVIDED IN THE BID FORM**

Dated at Zanesville, Ohio
October 6, 2025

MCEO
109 Graham Street
Zanesville, OH 43701

S:\Design\MCSDBoggs Rd Sewer\Bidding Information\Addendum No 1_20251006\001 MUS-Boggs Road Sewer-Addendum No 1-Memo.docx