



109 Graham Street
Zanesville, Ohio 43701
Phone - 740-454-0155
Fax - 740-455-7180

Mark J. Eicher, P.E., P.S. - Muskingum County Engineer

Engineer@mceo.org

Addendum No. 3
Cranberry Lane, Licking Township
Culvert Replacement

April 2, 2024

RE: Construction Plans – clarification (Alternate Bid)

The Title Sheet (Sheet 1) states in the project description that the existing 84 inch diameter culvert could be replaced with an 84 inch diameter culvert. However, there is no alternate bid and this option is not permitted. The existing culvert will be replaced with a 7 FT by 6 FT reinforced concrete box culvert.