

GENERAL NOTES

1. TYPES OF PAVEMENT SURFACES AS INDICATED ON THE PLANS REFER ONLY TO THE APPARENT SURFACE MATERIALS. THE CONTRACTOR SHALL VERIFY TO HIS OWN SATISFACTION THE TYPE OF SURFACE AND BASE OF EACH STREET PRIOR TO THE SUBMISSION OF BIDS. PAVEMENT REPLACEMENT SHALL CONSIST OF THE SAME TYPES OF SURFACE AND BASE MATERIALS AS REMOVED. THE ALLOWABLE WIDTHS OF TRENCH FOR PAYMENT ARE SHOWN IN THE SPECIFICATIONS. NO EXTRA PAYMENT WILL BE ALLOWED FOR DRIVEWAYS AND PARKING AREAS REPLACED.
2. EXACT LOCATION OF EACH END MANHOLE (M.H) OR CLEANOUT (C.O) SHALL BE VERIFIED IN THE FIELD DURING CONSTRUCTION, BY COUNTY
3. CONTRACTOR SHALL STATE IN HIS BID PROPOSAL, THE TYPE OF GRAVITY SEWER PIPE, FROM THOSE LISTED IN THE SPECIFICATIONS, UPON WHICH HIS BID IS BASED.
4. ALL FORCE MAIN SHALL BE P.V.C. SDR (21).FITTINGS TO BE DUCTILE IRON.
5. ALL V.G.S. SYSTEM PIPE TO BE P.V.C. SDR 26 - FITTING TO BE P.V.C. OR DUCTILE IRON.
6. MANHOLES WILL BE PAID FOR AT A LUMP SUM PRICE EACH FOR MANHOLES UP TO 10 FEET DEEP. MANHOLES IN EXCESS OF 10 FEET SHALL BE PAID FOR AT THE LUMP SUM PRICE PLUS THE CONTRACT UNIT PRICE PER VERTICAL FOOT OF MANHOLE IN EXCESS OF 10 FOOT.
7. DROP PIPES FOR MANHOLES WILL BE PAID FOR AT THE LUMP SUM PRICE EACH UP TO 6 FEET INVERT TO INVERT PLUS THE CONTRACT UNIT PRICE PER VERTICAL FOOT OF DROP IN EXCESS OF 6 FOOT.
8. CONTRACT PRICE PER LINEAL FOOT OF SEWER OR V.G.S. SYSTEM IS PAID THRU ALL HOUSE LATERAL WYES; THE CONTRACT UNIT PRICE PER WYE CONNECTION THEREFORE SHALL ONLY REFLECT THE DIFFERENCE BETWEEN THE WYE AND THE L.F. OF MAIN LINE.
9. PERMANENT AND CONSTRUCTION EASEMENTS WILL BE PROVIDED IN THE WIDTH AT THE LOCATIONS AS SHOWN ON THE DRAWINGS.
10. AT NIGHT AND AT ALL TIMES WHEN WORK IS NOT IN PROGRESS, THE CONTRACTOR SHALL PROTECT ANY OPEN TRENCH AND/OR EXCAVATION BY PLACEMENT OF A PROPERLY SECURED "SNOW FENCE" AROUND THE EXCAVATION. IN ADDITION TO NECESSARY BARRICADES, LIGHTS AND OTHER PROTECTIVE MEASURES DEAMED NECESSARY.

OWNERS OF PUBLIC UTILITIES

Call before you dig or drill underground. Ohio Utilities Protection Service 1-800-362-2764	City of Zanesville Fred Grant, III, F.E. Director of Public Services 4th and Market Zanesville, Ohio 43701 (614) 455-0650
Maysville Regional Water District Robert Riggs 6255 Maysville Pike P.O. Box 1700 South Zanesville, Ohio 43701 (614) 849-2428	Village of South Zanesville Marvin Savage, Superintendent Water and Sewer Dept. 7 Shawnee Avenue S. Zanesville, Ohio 43701 (614) 453-3113
Ohio Bell Telephone Mike Hill, Field location 840 Orchard Street Zanesville, Ohio 43701 (614) 454-3559	County Sanitary Engineer Dept. Cosmo Bertino, P.E., County Sanitary Engineer 1410 Newark Road P.O. Box 3248 Zanesville, Ohio 43701 (614) 452-4940
Cable Entertainment of Ohio, Inc. John Barber 737 Howard Street Zanesville, Ohio 43701 (614) 452-5414	Ohio Power Company Ron Geese 113 N. 5th Street Zanesville, Ohio 43701 (614) 452-5461
Columbia Gas Company Karl Baumgardner 99 North Front Street Columbus, Ohio 43216-0117 1-800-282-0146	Columbia Gas Company B. V. Perry 2429 Linden Street Zanesville, Ohio 43701 (614) 452-5467

LEGEND

EXISTING :

	Gas Line
	Water Line
	Water Valve
	Water Meter
	Catch Basin
	Sanitary Sewer
	Sanitary Manhole
	Power Pole
	Gravel
	APPROXIMATE Location of Existing Sanitary Facilities.
	Subdivision Boundary

PROPOSED :

	Variable Grade Sewer (V.G.S.)
	Gravity Sewer
	Force Main
	Lift Station
	Surge Tank
	Wet Well - S.T.E.P.
	Sanitary Manhole
	Encasements
	Clean Out

VERTICAL CONTROL :

Elevations shown on this plan are 1.97 feet above N.G.V.D. 1929.

Revisions

Date	By	Date	By
9-2-82	J.L.R.	9-2-82	J.L.R.

LEGEND & GENERAL NOTES

Maysville III Area Wastewater Project  
CONTRACT DIVISION A

MUSKINGUM COUNTY, OHIO

Design  
Enterprise