

Depth Of Service Line At R/W To Be Determined In The Field By The Contractor For Each Individual User. Slanted Stacks May Be Provided Where The Depth Of Sewer Is Greater Than Required For Service Line. Payment For Service Lines To Be On A Unit Price Basis, Per Lineal Foot Installed. Payment For Wye, Saddle, Or Fitting In Main To Be At Contract Unit Price As Set Out In The Proposal.



* Where Soil is Stable Delete #2 Stone

Casing Pipe

Grout Ends Shut


Carrier Pipe (Included In Unit Price Cost Of Crossing In Place.)

Wood Skid Blocking

1/2" Drain Thru End Seal

HIGHWAY OR RAILROAD CROSSING DETAIL

See Plan & Proposal For Bid Length. Verify Crossing Details With Permit From Hwy. Or R.R. As To Length, Min. Thickness, Etc.



Designed by: R.S.	Date: 8-27-82	Checked by: J.L.R.	Date: 9-1-82
Drawn by: <i>G. J. Lloyd</i>	Date: 8-28-82	Approved by:	Date: 9-1-82

MISCELLANEOUS DETAILS

Maysville III Area Wastewater Project
CONTRACT DIVISION A

Area Wastewater

Design Enterprise

Scale
AS SHOWN

Sheet
6 of 6

